WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 76963
Permit No.
Basin 212

NOTICE OF INTENT NO. 18587

1. OWNER RIO PROPERTIES INC
MAILING ADDRESS C/O MARNELL CORRAO ASSOC
5541 S. POLARIS AVE LAS VEGAS, NV 89103

ADDRESS AT WELL LOCATION RIO HOTEL - WEST TWAIN
CONNECTOR/ PARCEL#162-17-301-010
LAS VEGAS, NV

2. LOCATION NE ¼ SW ¼ Sec. 17 T 21 N/S R 61 E CLARK County
PERMIT NO. Issued by Water Resources | Parcel No. 162-17-301-010 | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☒ Other Dewater

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☒ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Well #3 Twain Roadway | | | | |
| Caliche | xx2' | 0 | 6' | |
| Stiff sandy clay | | 6 | 30' | |

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

Date started 8/2 1999
Date completed 8/3 1999

8. WELL CONSTRUCTION
Depth Drilled 30' Feet Depth Cased 30' Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 24" Inches | 0 Feet | 30 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 14" | 36.7 | .250 | 0 | 30' |
| | | | | |
| | | | | |

Perforations:
Type perforation Machine
Size perforation 1/4x 2 1/2 x 8 21 per foot
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 30 feet to 0 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ALLEN DRILLING INC. Contractor
Address 4847 S. VALLEY VIEW Contractor
LAS VEGAS, NV 89103
Nevada contractor's license number 18916 issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1376
Signed By driller performing actual drilling on site or contractor
Date 9-4-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627