WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 76989
Permit No. 28160
Basin 153

NOTICE OF INTENT NO. 32372

1. OWNER WALTER L. PLASKETT
MAILING ADDRESS BOX 10
EUREKA, NEV 89316

ADDRESS AT WELL LOCATION

2. LOCATION NE ¼ NE ¼ Sec. 1 T. 21 N/S R. 53 E EUREKA County
PERMIT NO. 28160 (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	2	2
SAND & GRAVEL		2	41	39
CLAY		41	50	9
SAND GRAVEL		50	61	11
CLAY		61	119	58
BLACK SAND		119	126	7
CLAY		126	140	14
SAND & GRAVEL	8	140	148	8
CLAY		148	152	4
SAND & GRAVEL	4	152	156	4
CLAY		156	161	5
SAND GRAVEL	16	161	177	16
CLAY		177	183	6
SAND & GRAVEL	7	183	190	7
CLAY		190	232	42
SAND GRAVEL	16	232	248	16
CLAY		248	260	32
SAND & GRAVEL	7	280	287	7
CLAY & GRAVEL		287	292	5
CLAY		292	302	10
CLAY SOME GRAVEL		302	319	17
SAND GRAVEL	12	319	331	12
CLAY		331	335	4
SAND & GRAVEL	6	335	341	6
CLAY		341	345	4
SAND & GRAVEL	3	345	348	3
CLAY		348	352	4
SAND & GRAVEL	4	352	356	4
CLAY		356	365	9

Date started 5-9-99, 19
Date completed 5-14-99, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
1250	122	2 HOURS

8. WELL CONSTRUCTION
Depth Drilled 365 Feet Depth Cased 365 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
38 Inches		TOP Feet	50 Feet
28 Inches		50 Feet	356 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16		¼	0	356

Perforations:
Type perforation ⅛" ROSCO MOSS
Size perforation
From 140 feet to 190 feet
From 232 feet to 252 feet
From 260 feet to 356 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 FT
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From TOP feet to 356 feet

9. WATER LEVEL
Static water level 65 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WALTER L. PLASKETT (Contractor)
Address BOX 10 (Contractor)
EUREKA, NEV 89316
Nevada contractor's license number issued by the State Contractor's Board 11882
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 635
Signed James E. Hutt (By driller performing actual drilling on site or contractor)
Date 6-3-99

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627