WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 77016
Permit No.
Basin 108

NOTICE OF INTENT NO. 27279

1. OWNER Jaun Tiscareno
MAILING ADDRESS 126 N. Nevada ST
Yerington NV 89447

ADDRESS AT WELL LOCATION 16-A Fox Lane
Yerington NV 89447

2. LOCATION SW ¼ SE ¼ Sec. 8 T. 13 N/S R. 26 E. — Lyon County
PERMIT NO. — Issued by Water Resources
148-561-26 Parcel No.
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil-Sandy		0	4	4
Brown Clay		4	9	5
Coarse Sand-Small				
Gravel		9	15	6
Brown clay		15	17	2
Coarse Sand-Small				
Gravel		17	25	8
Brown clay		25	28	3
Fine To Coarse-				
Sand		28	37	9
Brown clay		37	41	4
Coarse Sand-				
Small Gravel		41	52	11
Brown clay		52	60	8
Brown clay-Coarse-				
Sand		60	92	32
Coarse Sand		92	96	4
Coarse Sand-Gravel-				
Clay		96	100	4
Coarse Sand-Gravel	X	100	108	8
Coarse Sand-Gravel-				
Few Rock	X	108	112	4
Coarse Sand-Gravel-				
Clay	X	112	116	4
Coarse Sand-Gravel	X	116	125	9
Coarse Sand-Gravel-				
Clay	X	125	132	7
Coarse Sand-Gravel	X	132	136	4
Clay-Coarse Sand		136	139	3

Date started 12-26, 1994
Date completed 1-3, 1995

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Bailed	25	7	1 HR
AirLift	50	100' Line	1 HR

8. WELL CONSTRUCTION
Depth Drilled 139 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10 5/8	0	139

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.72	.188	+1	139

Perforations:
Type perforation Sawed
Size perforation 3/32 x 3" x 6 Rows
From 79 feet to 139 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 139 feet

9. WATER LEVEL
Static water level 93 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Bros Drilling Contractor
Address 162 N. Bybee Lane Contractor
Yerington NV 89447
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed Larry Ogden By driller performing actual drilling on site or contractor
Date 6-26-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627