WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 77018
Permit No.
Basin DX

NOTICE OF INTENT NO. 25124

1. OWNER Patrick Thomas
MAILING ADDRESS 16632 Cantlay Van Nuys Calif 91406
ADDRESS AT WELL LOCATION 1 Herman Ln Yerington NV 89447

2. LOCATION NE ¼ NE ¼ Sec. 16 T. ~~12~~ 13 N/S R. 26 E. Lyon County
PERMIT NO. — (Issued by Water Resources) 14-581-27 (Parcel No.) — (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil-Sandy		0	3	3
Clayish-Sand		3	5	2
Coarse Sand		5	24	19
Clay-Coarse Sand		24	26	2
Clay-Coarse Sand-Rock		26	28	2
Coarse Sand-Gravel-Few Rock-Fill		28	38	10
Coarse Sand-Gravel		38	46	8
Coarse Sand-Gravel-Clay Fill		46	54	8
Coarse Sand-Gravel		54	70	16
Clay-Coarse Sand		70	75	5
Coarse Sand-Gravel-Fill		75	96	21
Coarse Sand-Gravel-Clay Fill		96	115	19
Clay-Coarse Sand		115	125	10
Fine To Coarse Sand		125	135	10
Clay-Fractured Rock		135	138	3
Fractured Rock	X	138	159	21

Date started 8-14, 1995
Date completed 8-20, 1995

RECEIVED 99 JUN 30 AM 11:55 STATE ENGINEERS OFFICE

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Bailed	20	42	1 HR

8. WELL CONSTRUCTION
Depth Drilled 159 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	159 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	160

Perforations:
Type perforation Sawed
Size perforation 3/32 x 3" x 6 Rows
From 139 feet to 159 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 159 feet

9. WATER LEVEL
Static water level 38 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Bros Drilling (Contractor)
Address 162 N. By Bee Ln. (Contractor)
Yerington NV 89447
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed [signature] By driller performing actual drilling on site or contractor
Date 6-29-99

(Rev. 3 91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627