WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

# STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 77021
Permit No.
Basin 179

NOTICE OF INTENT NO. 401948

1. OWNER REED DIST. INC.
MAILING ADDRESS 807 AVENUE F
ELY, NV 89301

ADDRESS AT WELL LOCATION REED R-PLACE SHELL
STATION 909 AVENUE F, ELY, NV

2. LOCATION SE 1/4 NW 1/4 Sec. 16 T 16N N/S R 63E E WHITE PINE County
PERMIT NO. WELL NO MW-9 (Issued by Water Resources) 2-055-00-7 (Parcel No.) TRACT OF LAND (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| ASPHALT | | 0 | .25 | .25 |
| SANDY CLAY | | .25 | 4 | 3.75 |
| MED GRAVEL & SAND | | 4 | 45 | 41 |
| COARSE GRAVEL & SAND | X | 45 | 85 | 40 |
| PLACED 6' OF 3/8" BENTONITE ABOVE SAND FROM 44-50' | | | | |
| PUMPED CEMENT/BENTONITE SLURRY FROM 12-44' | | | | |
| CEMENTED IN FLUSH MOUNT MONUMENT AT SURFACE | | | | |

Date started 1/7/99, 19__
Date completed 1/8/99, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 1-2 | | 1 HR. |

8. WELL CONSTRUCTION
Depth Drilled 85 Feet Depth Cased 85 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | | To | |
|---|---|---|---|---|---|
| 9 7/8 | Inches | 0 | Feet | 10 | Feet |
| 8 1/2 | Inches | 10 | Feet | 85 | Feet |
| | Inches | | Feet | | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 4.5 | PVC | SCH 80 | -.3 | 85 |

Perforations:
Type perforation MACHINE SLOT
Size perforation .020
From 55 feet to 85 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 12
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From 50 feet to 85 feet

9. WATER LEVEL
Static water level 70 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC (Contractor)
Address P.O.BOX 850 (Contractor)
ELKO,NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1654
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 1/14/99

USE ADDITIONAL SHEETS IF NECESSARY

RECEIVED 96 JAN 26 AM 9:45