

OFFICE USE ONLY
 Log No. 77027
 Permit No. 61055-56
 Basin 103

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 42135

1. OWNER MELNIKOFF ADDRESS AT WELL LOCATION 389 MOTTVILLE LANE
 MAILING ADDRESS 389 MOTTVILLE LANE GV, NV 89410

2. LOCATION SW 1/4 SE 1/4 Sec 3 T. 12 N. R. 19 E. Douglas County
 PERMIT NO. 27331 61056 Parcel No. 19 110 45 Subdivision Name NA

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	3	3
Sandy Clay		3	5	2
OG	✓	5	75	70
Brown Clay	✓	75	78	3
OG	✓	78	140	62
OG Cobbles	✓	140	200	60

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)
 From To
17.5 Inches 0 Feet 55 Feet
12 1/4 Inches 55 Feet 200 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>12 3/4</u>		<u>.250</u>	<u>+1</u>	<u>55</u>
		<u>.188</u>	<u>+2</u>	<u>200</u>

Perforations:
 Type perforation Mill Slot
 Size perforation 3/32
 From 140 feet to 200 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 55

Placement Method: Pumped
 Poured

Gravel Packed: Yes No
 From 55 feet to 200 feet

9. WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow 150 G.P.M. 10 P.S.I.
 Water temperature Cold °F Quality _____

Date started 6-16-99
 Date completed 6-23-99

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
<u>Bailer</u>	<u>1.50</u>	<u>20'</u>	<u>4</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name NV Drilling Inc. Contractor
 Address 75 Lemars Cr. Rd Carson City Contractor
 Nevada contractor's license number issued by the State Contractor's Board 13697-A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 6-26-99

RECEIVED
 99 JUL 19 AM 11:49
 STATE ENGINEERS OFFICE
 MELNIKOFF