

OFFICE USE ONLY  
 Log No. 77030  
 Permit No. \_\_\_\_\_  
 Basin 105

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28170

1. OWNER Eric Vindum ADDRESS AT WELL LOCATION 380 Hansen Lane  
 MAILING ADDRESS 1873 Cascade Crt. Carlsbadville NV 89410  
South Lake Tahoe Calif 96150  
 2. LOCATION SW 1/4 SW 1/4 Sec 34 T. 13 N. R. 19 E. Douglas County  
 PERMIT NO. 19-070-340 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Overburden Brown Clay</u>		<u>0</u>	<u>4</u>	<u>4</u>
<u>Gray Clay (bottle)</u>	<u>x</u>	<u>4</u>	<u>9</u>	<u>5</u>
<u>Gray Clay and Gray sand Black Silty SANDS</u>	<u>9</u>	<u>9</u>	<u>63</u>	<u>54</u>
<u>Gray Clay</u>		<u>63</u>	<u>87</u>	<u>24</u>
<u>Brown Rusty DG SANDS</u>		<u>87</u>	<u>95</u>	<u>8</u>
<u>Brown Clay Silty Clay Zone</u>		<u>95</u>	<u>139</u>	<u>44</u>
<u>Coarse DG SANDS and small DG GRAVELS</u>	<u>x</u>	<u>139</u>	<u>160</u>	<u>21</u>

8. WELL CONSTRUCTION  
 Depth Drilled 160 Feet Depth Cased 160 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 3/4 Inches To 160 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10 3/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>160</u>

Perforations:  
 Type perforation Well Slot  
 Size perforation 3 x 3/32  
 From 140 feet to 160 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 100 feet to 160 feet

Date started 8-7, 1999  
 Date completed 8-8, 1999

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30+</u>	<u>40</u>	<u>3 HRS</u>

9. WATER LEVEL  
 Static water level \_\_\_\_\_ feet below land surface  
 Artesian flow 3 G.P.M. 30+ P.S.I.  
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Capital City Well Drilling  
 Address 20 Kit Kat Drive Carson City, NV 89706  
 Nevada contractor's license number issued by the State Contractor's Board 41775  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905  
 Signed Michael J. Hack  
 By driller performing actual drilling on site or contractor  
 Date 8-8-99