



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19937

1. OWNER Robert Potter ADDRESS AT WELL LOCATION 318 So. 10th  
 MAILING ADDRESS 151 W. Brooks Ave. #H LAS VEGAS, NV.  
NLV, NV. 89030

2. LOCATION SE 1/4 NW 1/4 Sec. 20 T 20 N/S R. 61 E. CLARK County  
 PERMIT NO. 11309 Issued by Water Resources Parcel No. 1392020212 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other B-59

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Pulled 5" Liner layed + down depth 375' to 415'</u>				
<u>Pulled 6" Liner layed + down depth 375 to 178'</u>				
<u>Ripped 8" Casing w/ moss perforator to 50' from Surface of Well</u>				
<u>Run 3" Tremie pipe pumped Neat Cement fill pump would not pump. Then pulled 6 joints and repeated process time and again till well was completed.</u>				
<u>Then cut casing 4' below ground level</u>				

8. WELL CONSTRUCTION  
 Depth Drilled 415 Feet Depth Cased 415 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
<u>14</u> Inches	<u>0</u> Feet	<u>41</u> Feet
<u>12 1/4</u> Inches	<u>41</u> Feet	<u>111</u> Feet
<u>8 3/4</u> Inches	<u>111</u> Feet	<u>325</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10</u>	<u>34</u>	<u>3/8</u>	<u>0</u>	<u>41</u>
<u>8</u>	<u>26</u>	<u>3/8</u>	<u>31</u>	<u>152</u>
<u>6</u>	<u>22</u>	<u>3/8</u>	<u>138</u>	<u>325</u>
<u>5</u>	<u>18</u>	<u>3/8</u>	<u>325</u>	<u>415</u>

Perforations:  
 Type perforation torch cut  
 Size perforation 1/4 x 2 1/4 x 4  
 From 290 feet to 317 feet  
 From 395 feet to 415 feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
 Depth of Seal 50  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 325 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 60 °F Quality Good

Date started Oct 19 1999  
 Date completed Oct 21 1999

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name ADA Compliance Corp. Contractor  
 Address 3915 W. Hacienda Ave. Contractor  
#A-111 LV, NV. 89118  
 Nevada contractor's license number issued by the State Contractor's Board 0048704  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2021  
 Signed Michael Dale Wells  
 By driller performing actual drilling on site or contractor  
 Date Oct. 21 1999