WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 77211
Permit No.
Basin 108

NOTICE OF INTENT NO. 41358

1. OWNER Mike Weeks
MAILING ADDRESS #8 Mason Rd
Yerington, NV 89447

ADDRESS AT WELL LOCATION 70 Tognoli Lane

2. LOCATION SE 1/4 ____ 1/4 Sec. 12 T 12 N/S R 25 E Lyon County
PERMIT NO. ____ Issued by Water Resources
Parcel No. 12-301-09
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other ____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other ____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	6	
sand & gravel		6	38	32
coarse gravel w/sand		38	42	4
sand & gravel		42	80	38
coarse gravel/sand/clay		80	85	5
sand/gravel/clay		85	101	16
gravel & clay stringers		101	115	14
sand/gravel/clay		115	124	9

RECEIVED 99 JUL 29 AM 11:26 STATE ENGINEER'S OFFICE

Date started 7/10/99, 19__
Date completed 7/13/99, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
18		2 hrs.

8. WELL CONSTRUCTION
Depth Drilled 124 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11 Inches		0 Feet	50 Feet
9-7/8 Inches		50 Feet	124 Feet
____ Inches		____ Feet	____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8		.188	+2	120

Perforations:
Type perforation single row mill slot
Size perforation 1/8 x3
From 100 feet to 120 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 124 feet

9. WATER LEVEL
Static water level 39 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Humboldt Drilling & Pump Co., Inc. Contractor
Address 4675 W. Winnemucca Blvd Contractor
Winnemucca, Nevada 89445
Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2019
Signed [signature] By driller performing actual drilling on-site or contractor
Date 7/28/99