WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 77680
Permit No.
Basin 212

NOTICE OF INTENT NO. 19919

1. OWNER Kerr-McGee Chemical
MAILING ADDRESS 8000 W. Lake Mead Dr.
Henderson, NV 89015

ADDRESS AT WELL LOCATION Kerr-McGee Chemical
8000 W. Lake Mead Dr.
Henderson, NV 89015

2. LOCATION NW ¼ SW ¼ Sec. 12 T. 22 N/S R. 62 E. Clark County

PERMIT NO. Issued by Water Resources | 178-12-401-004 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other Deive Pipe

6. LITHOLOGIC LOG TR-3

Material	Water Strata	From	To	Thickness
Sand, Silty Sand, Gravel		-0-	27	27
Silt, Sandy Silt, Clayey Silt	21	29	190	163
Sand, Gravelly Sand		190	251	61

Date started September 10, 1999
Date completed September 13, 1999

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10		45 min.

8. WELL CONSTRUCTION
Depth Drilled 251 Feet Depth Cased 250 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
9-5/8 Inches	-0- Feet	251 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	PVC	Sch 40	-0-	249.5

Perforations:
Type perforation Mill Slot
Size perforation .020
From 219.5 feet to 249.5 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 213.7
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 213.7 feet to 251 feet

9. WATER LEVEL
Static water level 8.0 feet below land surface
Artesian flow No G.P.M. P.S.I.
Water temperature Cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Don Stratton for Beylik Drilling Contractor
Address 555 S. Harbor Blvd. Contractor
La Habra, CA 90631-6124
Nevada contractor's license number issued by the State Contractor's Board 0007055A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2011
Signed Donald Stratton
By driller performing actual drilling on site or contractor
Date December 10, 1999

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627