

**WELL DRILLER'S REPORT**

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 39442

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

1. OWNER AKINS CONSTRUCTION  
 MAILING ADDRESS 2160 RICE ROAD  
FALLON, NV 89406

ADDRESS AT WELL LOCATION 1585 ALLEN ROAD

2. LOCATION SE 1/4 SE 1/4 Sec. 36 T 19 N/S R 28 E CHURCHILL County

PERMIT NO. \_\_\_\_\_ 8-851-29 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
BR SAND		0	10	
BR CLAY		10	15	5
BR CLAY		15	40	25
GREY SAND		40	55	15
BLK SILT		55	65	10
GREY SAND		65	80	15
GREY SAND/CLAY		80	90	10
GREY CLAY		90	93	3
BR SAND	X	93	102	9

8. WELL CONSTRUCTION  
 Depth Drilled 102 Feet Depth Cased 102 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
<u>10 1/4</u> Inches	0	50
<u>6 5/8</u> Inches	50	102

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.9</u>	<u>.188</u>	<u>+2</u>	<u>102</u>

Perforations:  
 Type perforation MACHINE SLOT  
 Size perforation .80

From	feet to
<u>95</u>	<u>100</u>
_____	_____
_____	_____
_____	_____
_____	_____

Surface Seal:  Yes  No  
 Depth of Seal 50  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No

Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

RECEIVED  
 99 MAY 21 AM 10:59  
 STATE ENGINEERS OFFICE

9. WATER LEVEL  
 Static water level 8'3" feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COOL °F Quality UNTESTED

Date started 4/23/1999 1999  
 Date completed 4/24/1999 1999

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30</u>	<u>1 HR</u>	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WELSCO CORP. Contractor  
 Address P. O. BOX 888 Contractor  
FALLON, NV 89406  
 Nevada contractor's license number issued by the State Contractor's Board 11752  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996

Signed [Signature]  
 By driller performing actual drilling on-site or contractor

Date 5/10/99