WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78137
Permit No.
Basin 105

NOTICE OF INTENT NO. 40307

1. OWNER Joe and Cindy Cirone
MAILING ADDRESS
ADDRESS AT WELL LOCATION

2. LOCATION SE ¼ NE ¼ Sec. 34 T. 13 X N/S R. 20 East Douglas County
PERMIT NO. Issued by Water Resources | 23-260-88 Parcel No. | Subdivision Name

3. WORK PERFORMED
XX New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
XX Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable X Rotary ☐ RVC
☐ Air ☐ Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown D G		0	7	7
Sand fine,brown		7	15	8
Brown clay W/ multi				
colored gravels		15	25	10
Multi colored				
Course sand & gravels		25	35	10
Brown Clay		35	50	15
Multi colored sand &				
brown clay		50	60	10
Multi colered Sand &				
gravels (course)		60	95	35
Brown clay		95	97	2
Multi colored gravels				
W/ course sand		97	105	8
Brown clay		105	108	3
Multi colored gravel				
W/ brown clay		108	115	7
Sand w/brown clay		115	119	4
Brown clayw/ multi				
colored sand &gravels		119	120	1
Multi colored course				
sand & gravel	xx	120	140	20
T.D.	140			

Date started 8-5, 19 99
Date completed 8-10, 19 99

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump XX Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+	100	2hrs

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
10-5/8 Inches From 0 Feet To 140 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	13.92	.188	+2	140

Perforations:
Type perforation factory sawed
Size perforation 3/32 x 3
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: X Yes ☐ No
Depth of Seal 100
Placement Method: X Pumped ☐ Poured
Seal Type: X Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: X Yes ☐ No
From 140 feet to 100 feet

9. WATER LEVEL
Static water level 10 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A.S.A.P. Pump & Well Service, Inc. (Contractor)
Address P.O. Box 60130 (Contractor)
Reno, Nevada 89506
Nevada contractor's license number issued by the State Contractor's Board 0035387-A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2066
Signed (By driller performing actual drilling on site or contractor)
Date 8-10-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627