

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37298

1. OWNER Homero Nunez ADDRESS AT WELL LOCATION: 3190 Mary  
 MAILING ADDRESS: P.O. Box 3765 Winnemucca, NV 89446 D-9 Winnemucca, NV  
 2. LOCATION: SE 1/4 NW 1/4 Sec. 12 T. 35 N. S. R. 37 E. Humboldt County  
 PERMIT NO. Domestic 013-445-10 Subdivision Name

3. WORK PERFORMED:  New Well  Replace  Recondition  Deepen  Abandon  Other  
 4. PROPOSED USE:  Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock  
 5. WELL TYPE:  Cable  Rotary  RVC  Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Topsoil</u>		<u>0</u>	<u>10</u>	<u>10</u>
<u>Clay</u>		<u>10</u>	<u>60</u>	<u>50</u>
<u>Sand + Rock</u>		<u>60</u>	<u>90</u>	<u>30</u>
<u>Clay</u>		<u>90</u>	<u>100</u>	<u>10</u>
<u>Sand + Gravel</u>	<u>yes</u>	<u>100</u>	<u>120</u>	<u>20</u>

8. WELL CONSTRUCTION  
 Depth Drilled: 120 Feet Depth Cased: 120 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To +0 Feet 120 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>10</u>	<u>.155</u>	<u>+1</u>	<u>120</u>

Perforations:  
 Type perforation: Fracture Cut  
 Size perforation: 3/32 x 4  
 From 100 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
 Depth of Seal: 60  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 60 feet to 120 feet

9. WATER LEVEL  
 Static water level: 57 feet below land surface  
 Artesian flow: N/A G.P.M. N/A P.S.I.  
 Water temperature: 60.1 °F Quality: Good

Date started: JAN 28 19 99  
 Date completed: JAN 30 19 99

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
		<u>4.5</u>	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name: Fred Anderson Contractor  
 Address: 10760 Grass Valley Rd Contractor  
Winnemucca, NV 89445  
 Nevada contractor's license number issued by the State Contractor's Board: 021467  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 2083  
 Signed: Chris Klein  
 By driller performing actual drilling on site or contractor  
 Date: JAN 30 99