WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78256
Permit No.
Basin 191

NOTICE OF INTENT NO. 3183R

1. OWNER Robert Brown
MAILING ADDRESS 1772 N 1790 W.
Fairfield UT 84013

ADDRESS AT WELL LOCATION
JLJ Subdivision Pilot Valley

2. LOCATION SW ¼ SE ¼ Sec. 1 T. 37 N/S R. 69 E/W Elko County
PERMIT NO. NA (Issued by Water Resources) Parcel No. Lot 4 Blk B Unit 2 JLJ Ranches (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [X] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
medium gravel w/sand	No	0	20	20
medium-coarse gravel	No	20	50	30
medium-fine gravel	No	50	80	30
Sandy fine gravel	No	80	90	10
medium gravel/minor sand	No	90	100	10
fine gravel + sand	No	100	110	10
fine-medium gravel w/moderate clay	No	110	120	10
fine gravel/heavy clay	No	120	130	10
coarse boulders/mostly	yes	130		
siliceous	yes		140	10
fine gravel + clay	yes	140		
minor sand			150	10
coarse gravel +	yes	150		
boulders-siliceous			190	40
coarse gravel w	yes	190		
limey coating			200	10

RECEIVED 99 SEP 21 PM 12:01 STATE ENGINEER'S OFFICE

Date started 9-9, 1999
Date completed 9-11, 1999

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40	8-10'	4 Hrs

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 7/8 Inches		0 Feet	200 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.7	0.188	0	200

Perforations:
Type perforation milled slot
Size perforation 1/8 x 3
From 136 feet to 196 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal Cemento-55; Bentonite grout; 55-120
Placement Method: [X] Pumped [ ] Poured
Per telcon w/Gustin Matt 9-21
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 120 feet to 200 feet

9. WATER LEVEL
Static water level 120 feet below land surface
Artesian flow NO G.P.M. P.S.I.
Water temperature 62 °F Quality fair

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Gustin Corp. (Contractor)
Address P.O. Box 894 (Contractor)
Elko NV 89803
Nevada contractor's license number issued by the State Contractor's Board 0022193
Nevada driller's license number issued by the Division of Water Resources, ~~the on-site driller~~ 1821
Signed [signature] (By driller performing actual drilling on site or contractor)
Date Sept. 14, 1999

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627