

REPORT NO. 99.62

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

LOG NO. 78346
PERMIT NO. 87
BASIN

NOTICE OF INTENT NO. 43165

OWNER Mountian View Cementary
MAILING ADDRESS Po Box 5118 Reno, Nevada 89503

ADDRESS OF WELL 435 Stoker
Reno, Nevada

2. WELL LOCATION SE 1/4 SE 1/4 SEC 9 T 19N R 19E E Washoe COUNTY
PERMIT NO. 61578 PARCEL NO. 006-152-02 SUBDIVISION NAME

3. TYPE OF WORK
 New Well Replace Recondition
 Deepen Plug Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Heavy clay		5	10	5
Sand and clay		10	12	2
Volcanic rock and clay		12	14	2
DG gravel, sand and clay		16	19	3
Heavy brown clay		19	20	1
Clay and some gravel		20	25	5
Boulders and cobbles		25	65	40
Gravel and clay		65	75	10
Heavy clay		75	81	6
Gravel and brown clay		81	90	9
Heavy clay		90	95	5
Gravel and clay		95	115	20
Heavy brown clay and rock		115	175	60
Pure heavy brown clay		175	190	15
Brown clay and gravel		190	245	55
Gray clay		245	290	45
Gray clay and black rock		290	330	40
Gray and brown clay and rock		330	465	135
Heavy gray and green clay		465	485	20
Green clay and heavy fine rock		485	530	45
Small gravel and gray clay	X	530	565	35
Heavy gray clay		565	575	10
Gray clay small rock and gravel	X	575	600	25

8. WELL CONSTRUCTION
 Depth Drilled 600 Depth Cased 600

HOLE DIAMETER (BIT SIZE)
12 1/4 Inches 0 Feet 100 Feet
10 5/8 Inches 100 Feet 600 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
8 5/8	16.94	.188	+2	600

PERFORATIONS:
 Type Perforation Factory Size Perforation 3/32 x 3 double
 From 180 Feet to 220 Feet
 From 520 Feet to 580 Feet
 From _____ Feet to _____ Feet

SURFACE SEAL: Yes No SEAL TYPE:
 Neat Cement
 Seal Depth 100 Cement Grout
 PLACEMENT METHOD: Pumped Concrete Grout
 Poured
 GRAVEL PACKED: Yes No
 From 100 Feet to 600 Feet

Notes :
 Date Started 10/21/99 Date Completed 11/2/99

9. WATER LEVEL
 Static Water Level 112 Feet Below Land Surface
 Artesian Flow _____ GPM _____ PSI
 Water Temperature Cool F Quality Clear

7. WELL TEST DATA

TEST METHOD Bailor Pump Air Develop

GPM	DRAWDOWN	TIME (HRS)
200+		2.5
250	141'	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & well Service, Inc
 Address 675 Edison Way
Reno, Nevada 89502
 NV. CONTRACTOR'S LIC. NO. 15291 DRILLER'S LIC. NO. _____
 ON SITE 1981
 Signed Roger M. Threl
 By driller performing actual drilling on site or contractor
 Dated November 3, 1999