

OFFICE USE ONLY
 Log No. **79000**
 Permit No. **162**
 Basin **162**

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO18019

1. OWNER Rodowick Family Trust ADDRESS AT WELL LOCATION Frontage Rd
 MAILING ADDRESS 3150 Alexandra Pahrump, NV 89048
 2. LOCATION SE 1/4 SE 1/4 Sec 27 T 19S N/S R 53E E Nye County
 PERMIT NO. 33-451-09 33-451-09 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Surface		0	4	4
Large rocks/clay		4	26	22
Small gravel w/clay		26	52	26
Grey clay		52	65	13
Rocks & clay		65	120	55
Brown clay	x	120	185	65
Rocks, small gravel with clay	x	185	200	15

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 200 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17	.188	0	200

Perforations:
 Type perforation Torch cut
 Size perforation 1/4" x 8" long
 From _____ feet to _____ feet
 From 160 feet to 200 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 200 feet

Date started 2-8-00, 19____
 Date completed 2-11-00, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50	-0-	15

9. WATER LEVEL
 Static water level 88 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Charles Nyberg Well Drilling Contractor
 Address 1060 W. Basin Rd Contractor
Pahrump, NV 89048
 Nevada contractor's license number issued by the State Contractor's Board 7484
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725
 Signed Charles Nyberg (Signature)
 By driller performing actual drilling on site or contractor
 Date 3-7-00