

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **19060**

1. OWNER Pete Ruelle ADDRESS AT WELL LOCATION 281 S. Bliss Rd  
 MAILING ADDRESS 281 S. Bliss Rd  
Pahrump, Nevada 89048  
 2. LOCATION NW 1/4 NW 1/4 Sec 15 T 20 N R 53 E Nye County Nye  
 PERMIT NO. 35-321-07 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_  
 Issued by Water Resources

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Silt		0	5'	5'
gravel/clay		5'	10'	5'
brown clay		10'	50'	40'
gravel		50'	55'	5'
brown clay		55'	65'	10'
caliche		65'	75'	10'
brown clay		75'	100'	25'
caliche		100'	105'	5'
brown clay		105'	140'	35'

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140' Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
12 Inches 0 Feet 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.625</u>	<u>4.33</u>	<u>.316</u>	<u>0</u>	<u>140</u>

Perforations:  
 Type perforation saw cut  
 Size perforation 1/8" x 3"  
 From 130 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 55 \_\_\_\_\_  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 140 feet

9. WATER LEVEL  
 Static water level: 20' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started Jan 10 2020  
 Date completed Jan 12 2020

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Lake Construction Co. Contractor  
 Address 4191 S. Packie St. Contractor  
Pahrump, Nevada 89048  
 Nevada contractor's license number 0049225  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 2116  
 Division of Water Resources, the on-site driller  
 Signed Foreest Lake  
 By driller performing actual drilling on site or contractor  
 Date Jan 12, 2020