

Log No. 79013  
 Permit No. 105  
 Basin

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

NOTICE OF INTENT NO. 39056

1. OWNER DAVE MILLS ADDRESS AT WELL LOCATION SAME  
 MAILING ADDRESS BEACON FOOD MART  
1603 HWY 375 MINDEN N.V.  
 2. LOCATION SE 1/4 SW 1/4 Sec. 29 T 13 R 20 E County DOUGLAS  
 PERMIT NO. 25-180-090 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  Other SPRINKLER  
 Deepen  Abandon

4. PROPOSED USE  
 Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other APR

6. LITHOLOGIC LOG SP # 5

Material	Water Strata	From	To	Thick-ness
Clay Cobble		0	9	9
GRAVELLY CLAY	12	9	24	15
GRAVELLY SAND		24	30	6

8. WELL CONSTRUCTION  
 Depth Drilled 30 Feet Depth Cased 30 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 6 Inches To 0 Feet 30 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
1	PVC	3/4	0	30

Perforations:  
 Type perforation \_\_\_\_\_  
 Size perforation \_\_\_\_\_  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No  
 Depth of Seal N/A 26  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 30 feet to 26 feet

Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Bentonite

9. WATER LEVEL  
 Static water level \_\_\_\_\_ feet below land surface  
 Artesian flow N/A G.P.M. N/A V.S.I.  
 Water temperature 60 °F Quality N/A

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name ANDERSON DRILLING Contractor  
 Address 1635 BELFORD RD Contractor  
KEWO N.V. 89509  
 Nevada contractor's license number 31525  
 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the M108T-1  
 Division of Water Resources, the on-site driller  
 Signed Amos Moore  
 By driller performing actual drilling on site or contractor  
 Date 2-16-99

Date started 2-3, 1999  
 Date completed 2-3, 1999

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	<u>N/A</u>	