

279

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY

Log No. 79065

Permit No. 105

Basin 105

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 39413

1. OWNER DAVE MILLS ADDRESS AT WELL LOCATION Bentley INV. CORP
 MAILING ADDRESS 1603 Hwy 395 1617 WATER ST.
MINDEN, NV 89428 MINDEN NV 89428

2. LOCATION SE 1/4 SW 1/4 Sec 29 T. 13 N. R. 20 E. Douglas County
 PERMIT NO. 1320-29-402-006 MINDEN BEADON
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED

New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE

Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE

Cable Rotary RVC
 Air Other SEAL

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Silt, sand, + Clay</u>		<u>0</u>	<u>68</u>	<u>68</u>
<u>GRAVEL, sand</u>		<u>68</u>	<u>75</u>	<u>7</u>
<u>sand, silt</u>		<u>75</u>	<u>83</u>	<u>8</u>
<u>Clay</u>		<u>83</u>	<u>87</u>	<u>4</u>
<u>sand + GRAVEL</u>		<u>87</u>	<u>109</u>	<u>22</u>
<u>Clay</u>		<u>109</u>	<u>110</u>	<u>1</u>

8. WELL CONSTRUCTION

Depth Drilled 110 Feet Depth Cased 110 Feet

HOLE DIAMETER (BIT SIZE)

From 0 To 110

8.5 Inches 0 Feet 110 Feet

Inches Feet Feet

Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.5</u>		<u>SC 40</u>	<u>0</u>	<u>110</u>

Perforations:

Type perforation factory

Size perforation 0.230

From 90 feet to 110 feet

From feet to feet

From feet to feet

From feet to feet

From feet to feet

Surface Seal: Yes No Seal Type: Neat Cement

Depth of Seal 83 feet Cement Grout

Placement Method: Pumped Poured Concrete Grout

Gravel Packed: Yes No

From 87 feet to 110 feet

9. WATER LEVEL

Static water level 9.2 feet below land surface

Artesian flow G.P.M. P.S.I.

Water temperature °F Quality

Date started 1-16-2000

Date completed 1-9-2000

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Robert Reed Contractor

Address 2223 W. Seldow Lane Contractor

Peoria, AZ 85345

Nevada contractor's license number issued by the State Contractor's Board 0021976

Nevada driller's license number issued by the Division of Water Resources, the on-site driller M.2071

Signed Robert Reed
By driller performing actual drilling on site or contractor

Date 1-25-2000