

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY

Log No. 79108

Permit No. 61

Basin 61

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 43224

1. OWNER Barrick Goldstrike ADDRESS AT WELL LOCATION Barrick Goldstrike Minesite, North of Carlin, NV

MAILING ADDRESS P.O. Box 29
Elko, NV 89803

2. LOCATION SW 1/4 SE 1/4 Sec 19 T. 36 N/S R. 50 E. Eureka County

PERMIT NO. N/A Parcel No. N/A Subdivision Name N/A

Issued by Water Resources

3. WORK PERFORMED

New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE

Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE

Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Abandoned by pumping neat cement from T.D. to surface				
Used 15 cu.ft. of cement				
1: 7 cu.ft.				
2: 4.25 cu.ft.				
3: 3.75 cu.ft.				
Construction Detail				
Cement		0	50	
Hole Plug		50	312	
Gravel Pack		312	330	
Hole Plug		330	388	
Gravel Pack		388	405	
Hole Plug		405	635	
Gravel Pack		635	655	

8. WELL CONSTRUCTION

Depth Drilled 655 Feet Depth Cased 650 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
14.75 Inches	0	55
8.250 Inches	55	655

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10.750	34.24	0.250	+2	55
1: 1.66	2.27	0.140	+1	650
2: 1.66	2.27	0.140	+1	400
3: 1.66	2.27	0.140	+1	325

Perforations: Drilled Holes

Type perforation 0.187"

From	To
1: 645	650
2: 395	400
3: 320	325

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout

Depth of Seal 50

Placement Method: Pumped Poured

Gravel Packed: Yes No See Detail

From.....feet to.....feet

Date started 31 August 1999

Date completed 31 August 1999

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL

Static water level All tubes dry feet below land surface

Artesian flow.....G.P.M.....P.S.I.

Water temperature.....°F Quality.....

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lang Exploratory Drilling Contractor

Address P.O. Box 5279 Contractor

Elko, NV 89802

Nevada contractor's license number issued by the State Contractor's Board.....0021976

Nevada driller's license number issued by the Division of Water Resources, the on-site driller.....2085

Signed Daniel Kohlman
By driller performing actual drilling on site or contractor

Date.....

B.S.C