


STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 79118
 Permit No. 2
 Basin Y 2



WELL DRILLER'S REPORT

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 437

1. OWNER Canyon General Improvement District ADDRESS AT WELL LOCATION near Lockwood
 MAILING ADDRESS 501 Rue de la Blanc
Sparks, NV 89434

2. LOCATION SE 1/4 SW 1/4 Sec. 17 T 19N N/S R 21E E Storey County
 PERMIT NO. W-519-A Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE Domestic Irrigation Test Stock Municipal/Industrial Monitor Air Rotary RVC Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
yellow clay		0	20	
blue/green clay		20	75	55
gray clay		75	80	5
purple clay		80	86	6
gray clay		86	215	129
purple clay		215	225	10
blue clay		225	240	15
basalt		240	280	40
red clay		280	320	40

ABANDON
 This well was abandon by pumping cement grout from the bottom of the borehole to the surface

8. WELL CONSTRUCTION
 Depth Drilled 320 Feet Depth Cased 0 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
8-1/2 Inches 0 Feet 190 Feet
7-7/8 Inches 190 Feet 320 Feet
 Inches Feet Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
n/a				

Perforations:
 Type perforation n/a
 Size perforation n/a
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 20 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

Date started 1/24/00, 19
 Date completed 2/1/00, 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30</u>		<u>1 hr.</u>

9. WATER LEVEL
 Static water level 200 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature warm °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Humboldt Drilling & Pump Co., Inc. Contractor
 Address 4675 W. Winnemucca Blvd Contractor
Winnemucca, Nevada 89445
 Nevada contractor's license number issued by the State Contractor's Board 015234
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1713
 Signed [Signature] By driller performing actual drilling on-site or contractor
 Date 2/5/00