WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 79119
Permit No.
Basin 83

NOTICE OF INTENT NO. 437[illegible]

1. OWNER Canyon General Improvement District
MAILING ADDRESS 501 Rue de la Blanc
Sparks, NV 89434

ADDRESS AT WELL LOCATION near Lo[illegible]wood

2. LOCATION SE 1/4 SW 1/4 Sec. 17 T 19N N/S R 21E E Storey County
PERMIT NO. W-519-A
Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [X] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [X] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
yellow clay		0	20	
blue/green clay		20	75	55
gray clay		75	80	5
purple clay		80	86	6
gray clay		86	215	129
purple clay		215	225	10
blue clay		225	240	15
basalt		240	280	40
red clay		280	320	40
ABANDON				
This well was abandon by				
pumping cement grout				
from the bottom of the				
borehole to the surface		0	320	320

Date started 1/24/00, 19__
Date completed 2/1/00, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		1 hr.

8. WELL CONSTRUCTION
Depth Drilled 320 Feet Depth Cased 0 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8-1/2	Inches	0	Feet	190	Feet
7-7/8	Inches	190	Feet	320	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
n/a				

Perforations:
Type perforation n/a
Size perforation n/a
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 20
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 200 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature warm °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc. (Contractor)
Address 4675 W. Winnemucca Blvd (Contractor)
Winnemucca, Nevada 89445

Nevada contractor's license number issued by the State Contractor's Board 015234

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1713

Signed [signature] (By driller performing actual drilling on-site or contractor)

Date 2/5/00