REPORT NO. A00.010

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 79128
PERMIT NO.
BASIN 88

APN=045-534-07

NOTICE OF INTENT NO. 13900

1. OWNER Nicloas Galvez
MAILING ADDRESS 1070 Jason Drive Sparks NV 89434
ADDRESS OF WELL 5460 Wildwood Dr
Reno NV 89511

2. WELL LOCATION SE 1/4 NW 1/4 SEC. 2 T 17N R 19 E Washoe COUNTY

PERMIT NO ____ PARCEL NO 04-553-07 SUBDIVISION NAME Callahan Ranch

3. TYPE OF WORK
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Plug [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [X] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Brown clay & fine rock				
Boulder, DG & brown clay		0	30	30
Granite boulders,cemented gravels		30	45	15
Cemented gravels & brown clay		45	65	20
Cemented gravels & boulders		65	140	75
Cemented gravels, boulders, sand		140	180	40
alluviel fill & sand		180	200	20
DG, sand & gravels		200	230	30
DG, sand & heavy brown clay		230	260	30
Rock, sand, & brown clay		260	280	20
Some rock heavy brown clay		280	300	20
Brown clay & some rock		300	310	10
Brown clay & fine rock	x	310	358	48

Notes :

Date Started 3-2-00 Date Completed 3-7-00

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [X] Air Develop

	GPM	DRAWDOWN	TIME (HRS)
	20+		1.5

8. WELL CONSTRUCTION

Depth Drilled 358 Depth Cased 358

HOLE DIAMETER (BIT SIZE)

10 5/8 Inches 0 Feet 50 Feet
8 1/2 Inches 50 Feet 358 Feet
____ Inches ____ Feet ____ Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
6 5/8	12.92	.188	+2	358

PERFORATIONS:
Type Perforation Factory Size Perforation 3/32 x 3
From 318 Feet to 338 Feet
From ____ Feet to ____ Feet
From ____ Feet to ____ Feet

SURFACE SEAL: [X] Yes [ ] No
Seal Depth 50
PLACEMENT METHOD: [X] Pumped [ ] Poured

SEAL TYPE:
[X] Neat Cement
[ ] Cement Grout
[ ] Concrete Grout

GRAVEL PACKED: [X] Yes [ ] No
From 50 Feet to 358 Feet

9. WATER LEVEL
Static Water Level 140' Feet Below Land Surface
Artesian Flow ____ GPM ____ PSI
Water Temperature cool F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service, Inc.
Address 675 Edison Way
Reno NV 89502

NV. CONTRACTOR'S LIC. NO 16291 DRILLER'S LIC. NO. ON SITE 1981

Signed Roger Mitchell
By driller performing actual drilling on site or contractor

Dated March-08-00