WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 77102
Permit No.
Basin 09

NOTICE OF INTENT NO. 435

1. OWNER Charles & Wanda Brown
MAILING ADDRESS 50 Buckboard
Reno, NV 89506

ADDRESS AT WELL LOCATION 450 Branding Iron Road
Reno,Nevada 89506

2. LOCATION NW 1/4 NW 1/4 Sec. 12 T 23N N/S R 18E E Washoe County
PERMIT NO. 58108 Issued by Water Resources
078-254-08 Parcel No.
Rancho Haven Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [X] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy DG		0	128	128
Granite		128	248	120
Granite Broken	X	248	265	17
Sandy DG	X	265	297	32
Granite		297	335	38
DG	X	335	348	13

Date started 02/21/2000 , 19__
Date completed 03/01/2000 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
100+	200	6 hours

8. WELL CONSTRUCTION
Depth Drilled 350 Feet Depth Cased 348 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12-1/4	Inches	0	Feet	250	Feet
11	Inches	250	Feet	350	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8-5/8	16.9	.188	+2	348

Perforations:
Type perforation Factory sawed & wire wrapped screen
Size perforation 3/32 x 3 & .050 slot
From 208 feet to 288 feet
From 328 feet to 348 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50 feet
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 350 feet to 50 feet

9. WATER LEVEL
Static water level 30 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A.S.A.P. Pump & Well Service Contractor
Address P.O. Box 60130 Contractor
Reno,Nevada
Nevada contractor's license number issued by the State Contractor's Board 0035387-A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2121
Signed [signature] By driller performing actual drilling on-site or contractor
Date 03/06/2000

USE ADDITIONAL SHEETS IF NECESSARY