WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 79134
Permit No. 89
Basin
NOTICE OF INTENT NO. 43099

1. OWNER P + L LAUGHLIN
MAILING ADDRESS 5705 MADRAS CC, NV
ADDRESS AT WELL LOCATION 5705 MADRAS CC, NV 89704

2. LOCATION SW ¼ SW ¼ Sec. 14 T. 16 ⊗S R. 19 E. WASHOE County
PERMIT NO. (Issued by Water Resources) 055 163 03 (Parcel No.) NA (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
NDI HAD PULLED THE 5 9/16 LINER, DRILLED TO 500 FT W A 6 1/8 BIT INSTALLED A 5" PVC LINER SEALED IT IN PLACE, PUMPED THE WELL & EVIDENTLY THE PVC BROKE NEAR THE BOTTOM. NDI PULLED THE 5" PVC + RECOVERED ALL BUT THE BOTTOM 10 FT.				
A PERFORATOR WAS RUN TO THE BOTTOM OF THE 6" STEEL (250') + THE PIPE RIPPED TO 120'				
A TREMIE PIPE WAS INSTALLED TO A DEPTH OF 460 FT & NEAT CEMENT WAS PUMPED FROM 460 FT TO THE SURFACE.				

Date started 2/4, 1900
Date completed 2/7, 1900

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
2		

8. WELL CONSTRUCTION
Depth Drilled 500 Feet Depth Cased 500 Feet

HOLE DIAMETER (BIT SIZE)

		From		To
12 1/4 Inches		0 Feet		250 Feet
6 1/8 Inches		250 Feet		500 Feet
Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+2	250
5	PVC	.25	+3	500

Perforations:
Type perforation MACHINE
Size perforation 3x3/32 / .050
From feet to feet
From 190 feet to 250 feet
From feet to feet
From 460 feet to 500 feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 120
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow 1 G.P.M. P.S.I.
Water temperature COLD °F Quality ?

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name NEVADA DRILLING, INC (Contractor)
Address 75 LEWERS CRK RD (Contractor)
CC, NV 89704
Nevada contractor's license number issued by the State Contractor's Board 13697A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
Signed Joe Leisch (By driller performing actual drilling on site or contractor)
Date 2/8/00

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627