WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 79167
Permit No.
Basin 105

NOTICE OF INTENT NO. 41921

1. OWNER Glen Horton
MAILING ADDRESS Gardnerville NV 89410
ADDRESS AT WELL LOCATION 1978 Stephen Ct. Gardnerville NV 89410

2. LOCATION SE ¼ SE ¼ Sec. 1 T. 12 N/S R. 20 E. Douglas County
PERMIT NO. Issued by Water Resources | Parcel No. 23-190-29 | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
overburden		0	3	3
Cemented Gravels		3	67	64
Coarse Gravels and Sands Obsidian Gravels		67	135	68
Brown Solid Clay		135	290	155
Soft Sandy Zone	x	290	293	3
Brown Gummy Clay		293	317	24
Course Obsidian Sands	x	317	321	4
Brown Gummy Clay Strata		321	347	26
Coarse Soft Dk Sands	xx	347	360	13

Date started 3-6, 2000
Date completed 3-10, 2000

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25+	105	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 360 Feet Depth Cased 360 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	360 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	360

Perforations:
Type perforation Mill Slot
Size perforation 3 x 3/32
From 340 feet to 360 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 360 feet

9. WATER LEVEL
Static water level 190 feet below land surface
Artesian flow G.P.M. 25+ P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Capital City Well Drilling (Contractor)
Address 20 Kit Kat DR (Contractor)
Carson City NV 89706
Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 3-13-00

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627