WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 79173
Permit No.
Basin 72B

NOTICE OF INTENT NO. 43884

1. OWNER LINDA REICHLIN
MAILING ADDRESS 15650 Toll Road
Reno, Nevada 89511

ADDRESS AT WELL LOCATION 9360 North Virginia Street
Reno, Nevada 89506

2. LOCATION NE ¼ NW ¼ Sec. 16 T. 20N N/S R. 19 E. Washoe County
PERMIT NO. (Issued by Water Resources) 082-650-18 17 (Parcel No.) Black Springs Area (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown clay, boulders and gravels		1	15	14
Brown clay		15	18	3
Brown clay, boulders and gravels		18	29	11
Soft zone, brown sandy clay		29	31	2
Brown clay & gravels		31	48	17
Light brown sandy clay		48	103	55
Brown sandy clay		103	107	4
Brown sandy clay with gravels		107	143	36
Brown sticky clay		143	145	2
Brown sandy clay with gravels		145	210	65
Light brown clay with gravels		210	294	84
Brown sticky clay		294	301	7
Brown clay with gravels		301	346	45
Weathered granite with clay streaks		346	406	60
Fracture (app 5 GPM)	X	406	411	5
Weathered granite		411	438	27
Fracture rock (app 10GPM)	X	438	455	17
Weathered hard granite		455	460	5

Date started February 24, 2000 XX
Date completed February 28, 2000 XX

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15		

8. WELL CONSTRUCTION
Depth Drilled 460 Feet Depth Cased 460 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	100	Feet
8 5/8	Inches	100	Feet	460	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	460

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 395 feet to 455 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100 feet
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 460 feet

9. WATER LEVEL
Static water level 169 feet below land surface
Artesian flow G.P.M. 15 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510

Nevada contractor's license number issued by the State Contractor's Board 0022549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed [signature] (By driller performing actual drilling on site or contractor)
Date March 1, 2000

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627