

OFFICE USE ONLY
 Log No. 19196
 Permit No. 105
 Basin I

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 26844

1. OWNER Mike Bellik ADDRESS AT WELL LOCATION 400 Hansen Ln
 MAILING ADDRESS Gardnerville NV 89410 Gardnerville NV, 89410

2. LOCATION NE 1/4 NE 1/4 Sec 3 T 12 S R 19 E Douglas County
 PERMIT NO. 19-070-32 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>overburden</u>		<u>0</u>	<u>3</u>	<u>3</u>
<u>Coarse Sands</u>	<u>X</u>	<u>3</u>	<u>12</u>	<u>9</u>
<u>Surface Water</u>				
<u>Silty Brown Sands and DG Sands</u>		<u>12</u>	<u>63</u>	<u>51</u>
<u>Gray Silty Clay</u>		<u>63</u>	<u>112</u>	<u>49</u>
<u>Gray soft Silty Sands</u>		<u>112</u>	<u>136</u>	<u>24</u>
<u>Coarse Brown DG Sands and Clay</u>	<u>XX</u>	<u>136</u>	<u>160</u>	<u>24</u>

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 3/4 Inches To 0 Feet 160 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>160</u>

Perforations:
 Type perforation Mill Slot
 Size perforation 3 x 3/32
 From 140 feet to 160 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 160 feet

9. WATER LEVEL
 Static water level: Flowing feet below land surface
 Artesian flow: 5 G.P.M. 30 P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Capital City Well Drilling
 Address 20 Ket Ket Dr.
Carson City NV 89706
 Nevada contractor's license number issued by the State Contractor's Board 41775
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
 Signed Michael D. Mack
 By driller performing actual drilling on site of contractor
 Date 2-20-00

Date started 2-17 2000
 Date completed 2-18 2000

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30</u>	<u>20</u>	<u>3 HRS.</u>

RECEIVED
 30 FEB 22 PM 11:48
 STATE ENGINEERS OFFICE