EW-30

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 79200
Permit No. 61
Basin

NOTICE OF INTENT NO. 42865

1. OWNER BARRICK GOLDSTRIKE MINES
MAILING ADDRESS P.O. BOX 29
ELKO, NV 89803

ADDRESS AT WELL LOCATION BARRICK GOLDSTRIKE MINESITE, NORTH OF CARLIN, NV.

2. LOCATION SE ¼ SE ¼ Sec. 19 T 36 (N)S R 50 E EUREKA County
PERMIT NO. 61248T (Issued by Water Resources) | N/A (Parcel No.) | N/A (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial (mining) ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ABANDONED BY PUMP-				
ING ABANTONITE VIA				
TREMMIE FROM T.D.				
TO 90', THEN POUR-				
ED HOLE PLUG TO				
10', AND CEMENT				
TO SURFACE.				
QUANTITIES USED:				
ABANTONITE 1791 CU.FT.		90	1360	1270
HOLE PLUG 74 CU.FT.		10	90	80
CEMENT 8 CU.FT.		0	10	10

Date started FEBRUARY 2, 2000, 19
Date completed FEBRUARY 3, 2000, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 1380 Feet Depth Cased 1360 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
31 Inches	0 Feet	36 Feet
24 Inches	36 Feet	144 Feet
14.75 Inches	144 Feet	1380 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
24	94.62	0.375	0	36
20	78.60	0.375	0	144
12	33.38	0.250	0	1360

Perforations:
Type perforation LOUVER
Size perforation 0.125"
From 159 feet to 1360 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 144'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 36 feet to 1380 feet

9. WATER LEVEL
Static water level NOT AVAILABLE feet below land surface
Artesian flow N/A G.P.M. P.S.I.
Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LANG EXPLORATORY DRILLING (Contractor)
Address P.O. BOX 5279 (Contractor)
ELKO, NV 89802
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2143
Signed Brant Bowen (By driller performing actual drilling on site or contractor)
Date FEBRUARY 4, 2000

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627

BTL