

OFFICE USE ONLY
 Log No. 79204
 Permit No. 105
 Basin

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26845

1. OWNER Mitch Sawl ADDRESS AT WELL LOCATION: 3617 Silverado DR Carson City NV 89704
 MAILING ADDRESS: 3617 Silverado DR Carson City NV 89704
 2. LOCATION: SW 1/4 SW 1/4 Sec. 6 T. 14 S R. 20 E Douglas County
 PERMIT NO. 13-102-07 Parcel No. Jacks Valley Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|------------------------------------|--------------|------|-----|------------|
| Overburden | | 0 | 3 | 3 |
| Cemented DG Sands and Small Gravel | | 3 | 64 | 61 |
| Rusty DG Sands | | 64 | 94 | 30 |
| Brown Clay | | 94 | 161 | 67 |
| Small Clay Strata DG Sands | | 161 | 174 | 13 |
| Fractured DG Sands and Gravel | XXX | 174 | 200 | 26 |

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 3/4 Inches To 0 Feet 200 Feet
 Inches Feet Feet
 Inches Feet Feet
 CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>65/8</u> | <u>13.03</u> | <u>.188</u> | <u>0</u> | <u>200</u> |

Perforations:
 Type perforation Mill Slot
 Size perforation 3x 3/32
 From 180 feet to 200 feet
 From feet to feet
 From feet to feet
 From feet to feet
 From feet to feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 200 feet

Date started 2-9 1900
 Date completed 2-11 1900

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|-----------|-------------------------------|--------------|
| <u>25</u> | <u>35</u> | <u>3 HRS</u> |

9. WATER LEVEL
 Static water level 80 feet below land surface
 Artesian flow 0 G.P.M. 25 P.S.I.
 Water temperature 66 °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Capital City Well Drilling Contractor
 Address 20 K. Kat DR. Carson City NV 89706 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 41775
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
 Signed Michael Black By driller performing actual drilling on site or contractor
 Date 2-14-00