

266

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY

Log No. 79205

Permit No. 87

Basin 87

NOTICE OF INTENT NO. 15637

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Equiva Services, LLC ADDRESS AT WELL LOCATION 130 West Plumb Lane Reno, NV

MAILING ADDRESS PO Box 7864 Burbank, CA 91501

2. LOCATION NW 1/4 SW 1/4 Sec 24 T. 19 N. R. 19 E. Washoe County

PERMIT NO. 6500 Issued by Water Resources Parcel No. 019-051-09 Subdivision Name

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other

4. PROPOSED USE Domestic Municipal/Industrial Irrigation Test Monitor Stock

5. WELL TYPE Cable Rotary RVC Air Other

6. LITHOLOGIC LOG - MW-3

| Material | Water Strata | From | To | Thick-ness |
|---------------------|--------------|-----------|-----------|------------|
| <u>Sandy Gravel</u> | <u>damp</u> | <u>0</u> | <u>5</u> | <u>5</u> |
| <u>Silty Sand</u> | <u>damp</u> | <u>5</u> | <u>16</u> | <u>11</u> |
| <u>Clayey silt</u> | <u>dry</u> | <u>20</u> | <u>25</u> | <u>5</u> |
| <u>Silty Sand</u> | <u>wet</u> | <u>25</u> | <u>30</u> | <u>5</u> |

8. WELL CONSTRUCTION

Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

From 8" To 30"

Inches _____ Feet _____

Inches _____ Feet _____

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| <u>2"</u> | | <u>Sch. 40</u> | <u>0</u> | <u>30</u> |

Perforations:

Type perforation slot

Size perforation 0.030"

From 10 feet to 30 feet

From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout

Depth of Seal 6'

Placement Method: Pumped Poured

Gravel Packed: Yes No

From 5 feet to 30 feet

9. WATER LEVEL

Static water level 15.00 feet below land surface

Artesian flow _____ G.P.M. _____ P.S.I.

Water temperature _____ °F Quality _____

Date started 12/9/99, 19____

Date completed 12/9/99, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--------|-------------------------------|--------------|
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Gregg Drilling & Testing, Inc Contractor

Address 950 Howe Road Contractor

Martinez, CA

Nevada contractor's license number issued by the State Contractor's Board 0038113

Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2018-T1

Signed Archie Mung By driller performing actual drilling on site or contractor

Date 2/11/2000