

213

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY

Log No. 79229

Permit No. 72

Basin 72

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 43478

1. OWNER FLORIDA CANYON MINING ADDRESS AT WELL LOCATION FLORIDA CANYON MINESITE
MAILING ADDRESS P.O. BOX 330 8 MILES SW OF IMLAY, NV
IMLAY, NV 89418
2. LOCATION NE 1/4 SW 1/4 Sec. 2 T. 31 N. N/S R. 33 E. PERSHING County
PERMIT NO. NOTICE#39970 FLORIDA CANYON Parcel No. FLORIDA CANYON Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
MONITOR WELL RTP-10				
WELL ABANDONED				
HOLE WAS CHECKED FOR WATER.				
WATER AT 217 FT.				
20-245 FT. BENTONITE GROUT IN UPWARD DIRECTION FROM BOTTOM.				
7 - 50# BAGS OF BENTONITE MIXED WITH WATER.				
SURFACE TO 20 FT.				
1 - 94# BAG OF PORTLAND CEMENT MIXED WITH WATER.				

8. WELL CONSTRUCTION
 Depth Drilled 245 Feet Depth Cased 245 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2 3/8			0	245

Perforations:
 Type perforation.....
 Size perforation.....
 From.....feet to.....feet
 From.....feet to.....feet
 From.....feet to.....feet
 From.....feet to.....feet
 From.....feet to.....feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 20 FEET..... Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From.....feet to.....feet

Date started NOVEMBER 16 1999
 Date completed NOVEMBER 17 1999

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. 217 WATER LEVEL
 Static water level.....feet below land surface
 Artesian flow.....G.P.M.....P.S.I.
 Water temperature.....°F Quality.....

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name DELONG CONSTRUCTION & DRILLING, INC. Contractor
 Address P.O. BOX 907 Contractor
WINNEMUCCA, NV 89446
 Nevada contractor's license number issued by the State Contractor's Board 0002120C
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1775
 Signed 11.17.99
 By driller performing actual drilling on site or contractor
 Date 11.17.99