

213

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY

Log No. 79230
Permit No. 2
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 42478

1. OWNER FLORIDA CANYON MINING ADDRESS AT WELL LOCATION
MAILING ADDRESS P.O. BOX 300 FLORIDA CANYON MINESITE
IMLAY, NV 89418 8 MILES SW OF IMLAY, NV

2. LOCATION NW 1/4 NW 1/4 Sec. 2 T. 31 N N/S R. 33 E PERSHING County
PERMIT NO. NOTICE #39968 F.C. MINESITE N/A
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
MONITOR WELL RTP - 12				
WELL ABANDONED				
HOLE WAS CHECKED FOR WATER				
WATER AT 372 FEET				
FILLED FROM THE TOP				
335 TO 575 FEET				
8 - 50# PAILS OF PEL PLUG				
1/4 INCH COATED BENTONITE PELLETS				
20 TO 335 FEET				
10 TO 50# BAGS CHIPPED				
COARSE BENTONITE				
SURFACE TO 20 FEET				
1 - 94# BAG OF PORTLAND				
CEMENT WITH WATER				

8. WELL CONSTRUCTION
 Depth Drilled 585 Feet Depth Cased 575 Feet

HOLE DIAMETER (BIT SIZE)
 From To
 Inches Feet Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2 3/8			0	575

Perforations:
 Type perforation
 Size perforation
 From feet to feet
 From feet to feet
 From feet to feet
 From feet to feet
 From feet to feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 20 FEET Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From feet to feet

Date started OCTOBER 28, 19.99
 Date completed OCTOBER 29, 19.99

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
 Static water level 372 feet below land surface
 Artesian flow G.P.M. P.S.I.
 Water temperature °F Quality

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name DELONG CONSTRUCTION & DRILLING, INC. Contractor
 Address P.O. BOX 907 WINNEMUCCA, NV 89446 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 0002120C
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1775
 Signed *Kirk Shearman* By driller performing actual drilling on site or contractor
 Date 10