

OFFICE USE ONLY  
 Log No. 79298  
 Permit No. \_\_\_\_\_  
 Basin 163  
 NOTICE OF INTENT NO. 19783

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER CHRISTOPHER & NADINE SEQUIST  
 MAILING ADDRESS \_\_\_\_\_  
 ADDRESS AT WELL LOCATION HOPKI + UTAH SANDY VALLEY NV.  
 2. LOCATION SE 1/4 NE 1/4 NW 1/4 Sec. 5 T. 25 N. R. 57 E CLARK County  
 PERMIT NO. 29-05-101-025  
 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replce  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY LOAM		0	10	10
CLAY		10	46	36
CALICHE		46	52	6
CLAY		52	67	15
CALICHE	W.B	67	71	4
CLAY		71	81	10
CALICHE	W.B	81	96	15
CLAY + GRAVEL		96	108	12
GRAVEL	WB	108	116	8
GRAVEL + CLAY		116	130	14
GRAVEL	W.B	130	140	10

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>4.33</u>	<u>.316</u>	<u>0</u>	<u>140</u>

Perforations:  
 Type perforation FACTORY SCREEN  
 Size perforation 8 INCH BY 3 INCH  
 From 140 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 50  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 140 feet to 50 feet

Date started 3-14 2000  
 Date completed 3-17 2000

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL  
 Static water level 57 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.  
 Water temperature COOL °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name BUDGET DRILLING CO. Contractor  
 Address P.O. BOX 3505 Contractor  
PAHRUMP NV. 89041  
 Nevada contractor's license number 40020  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1573  
 Division of Water Resources, the on-site driller.  
 Signed Dennis Brown  
 By driller performing actual drilling on site or contractor  
 Date 3-20-2000