

# WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

Log No. 79323  
 Rec. 19  
 Well No. \_\_\_\_\_  
 Permit No. \_\_\_\_\_  
*Do not fill in*

Owner Jack Hansen Driller Hessinger Drill & Pump Serv

Address 2609 Pinto Lane Address Box 589 Lic. No. 212

Location of well:  $\frac{1}{4}$  Sec 22, T 20N, R 16E, in Clark County  
 or 2609 Pinto Lane

Water will be used for Domestic Refrigeration Total depth of well 50 feet

Size of drilled hole 10 Inch Weight of casing per linear foot 8.64 lbs.

Thickness of casing 10 Gauge Temp. of water \_\_\_\_\_

Diameter and length of casing 6"OD 50 feet  
 (Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)

If flowing well give flow in c.f.s. or g.p.m. and pressure \_\_\_\_\_

If nonflowing well give depth of standing water from surface 12' from top of casing

If flowing well describe control works \_\_\_\_\_  
 (Type and size of valve, etc.)

Date of commencement of well October 1, 1958 Date of completion of well October 4, 1958

Type of well rig "71 Speed Star"

### LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
<b><u>PUMP WELL</u></b>			
0	7	7	Clay
7	9	2	Sandstone
9	12	3	Clay
12	15	3	Cement Gravel
15	19	4	Gravel (Water)
19	27	8	White Clay
27	37	10	Cement Gravel
37	39	2	White Clay
39	41	2	Gravel (Water)
41	50	9	White Clay
<b><u>Discharge Well</u></b>			
0	7	7	Clay
7	9	2	Sandstone
9	12	3	Clay
12	15	3	Cement Gravel
15	19	4	Gravel (Water)
19	27	8	White Clay
27	30	3	Cement Gravel
30	33	3	White Clay & Gravel
33	37	4	Cement Gravel
37	40	3	White Clay
40	45	5	Limestone (Water)
45	50	5	White Clay

Water-bearing Formation, Casing Perforations, Etc.

Chief aquifer (water-bearing formation)

from 15 to 19 ft.

Other aquifers 39-41

First water at 15 feet.

Casing perforated from 30 to 50 ft.

Size of perforations 1/15" x 1/4"

LOG OF FORMATIONS—Continued

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
6"OD	0	50	50	Cemented from 0 to 12 feet 1 yard of concrete Graveled packed from 12 to 50 feet 2 yards of pea gravel

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

---



---



---



---



---



---

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Eringer Drill & Pump Serv.

Well Driller

By A. F. Eringer

License No. 212

Dated October 4, 58, 19  

(Not to be filled in by Driller)

---



---



---



---



---



---



---



---



---



---