WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 79418
Permit No.
Basin 162

NOTICE OF INTENT NO. 20565

1. OWNER AMERICAN BUILDERS CORP
MAILING ADDRESS 3260 WINCHESTER
PAHRUMP, NV 89048

ADDRESS AT WELL LOCATION 3260 WINCHESTER

2. LOCATION NW 1/4 SW 1/4 Sec. 32 T 20S N/S R 53E E NYE County
PERMIT NO. (Issued by Water Resources) 40-531-14 (Parcel No.) CALVADA VALLEY (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| CLAY | | 0 | 46 | 46 |
| CALICHIE | | 46 | 57 | 11 |
| CLAY | | 57 | 74 | 17 |
| CALICHIE | WB | 74 | 86 | 12 |
| CLAY | | 86 | 105 | 19 |
| CALICHIE | WB | 105 | 118 | 13 |
| CLAY | | 118 | 131 | 13 |
| CALICHIE | WB | 131 | 140 | 9 |

DCNR/DWR Received MAY 17 2000 LAS VEGAS OFFICE

Date started 5/10/2000, 19__
Date completed 5/14/2000, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | | To | |
|---|---|---|---|---|---|
| 10.25 | Inches | 0 | Feet | 140 | Feet |
| | Inches | | Feet | | Feet |
| | Inches | | Feet | | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6.625 | 3.63 | .280 | 0 | 140 |
| | | | | |

Perforations:
Type perforation SAW CUT
Size perforation 1/8 X 3
From 100 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 67 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. (Contractor)
Address P.O. BOX 4220 (Contractor)
PAHRUMP, NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan (By driller performing actual drilling on-site or contractor)
Date 5/6/2000

USE ADDITIONAL SHEETS IF NECESSARY