

OFFICE USE ONLY
 Log No. 79443
 Permit No. _____
 Basin 22
 19680

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. _____
 Las Vegas Valley Water District

1. OWNER City of Las Vegas Water ADDRESS AT WELL LOCATION Las Vegas Valley Water District
 MAILING ADDRESS 3617 N. 5th Street 6005 E. Vegas Valley Dr.
N. Las Vegas, NV 89032 Las Vegas, NV 89122
 2. LOCATION S 1/4 SW 1/4 Sec. 10 T. 21 N/S R. 62 E. Clark County
 PERMIT NO. DWIN13 161-10-401-003 Parcel No. _____ Subdivision Name _____
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other Dewater
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
25-Dewater wells				
Well #17, 18 & 19				
Silty		0'	5'	5'
Silty clay		5'	30'	25'
Well #16, 20, 21, 22 & 23				
Silty		0'	5'	5'
Silty clay		5'	40'	35'

8. WELL CONSTRUCTION
 Depth Drilled _____ Feet Depth Cased _____ Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
24" Inches 0' Feet 30' Feet
24" Inches 0' Feet 40' Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14"	36.71	1.250	0	30'
16"	36.71	1.250	0	40'

Perforations:
 Type perforation Machine
 Size perforation 1/4" x 2 1/2" x 3 rows @ 13
 From 10' feet to 30' feet
 From 20' feet to 40' feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to 30-40' feet

9. WATER LEVEL
 Static water level 5' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Date started 5/4/00 2000
 Date completed 5/4/00 2000

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

Name ALLEN DRILLING INC Contractor
 Address 4847 S. VALLEY VIEW
LAS VEGAS, NV 89103
 Nevada contractor's license number issued by the State Contractor's Board. 18917
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller. ABDS2161
 Signed David [Signature]
 By driller performing actual drilling on site or contractor
 Date 5/16/00

