WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 79451
Permit No.
Basin 212

NOTICE OF INTENT NO. 16829

1. OWNER Roy F. Weston Inc.
MAILING ADDRESS 14724 Ventura Blvd, Ste 1000 Sherman Oaks, CA 91403-3501
ADDRESS AT WELL LOCATION NEC Tropicana & Decatur Blvd

2. LOCATION SW ¼ SW ¼ Sec. 19 T. 21 N/S R. 61 E. Clark County
PERMIT NO. ~~[illegible]~~ Issued by Water Resources
162-19-401-011 Parcel No.
N/A Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill		0	4	4'
Silty Sand		4	10	6'
Sandy Silt		10	17	7'
Caliche		17	22	5'
Silty Clay		22	30	8'
Caliche		30	32	2'
Sandy Silt w/clay 37'		32	50	18'

NOTE ON INTENT CARD
Drilled & Plugged Same Day

Date started 5/8 2000
Date completed 5/8 2000

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 50' Feet Depth Cased 50 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6 Inches		0 Feet	50 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2" schedule 40			0	35
2" schedule 40		screen .010	35	50

Perforations:
Type perforation slotted
Size perforation .010
From 35 feet to 50 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 35'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 38 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Western Technologies Inc. Contractor
Address 3611 W. Tompkins Contractor
Las Vegas NV 89103
Nevada contractor's license number issued by the State Contractor's Board 0043295
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1761
Signed By driller performing actual drilling on site or contractor
Date 5/8/2000

DCNR/DWR Received MAY 4 2000 LAS VEGAS OFFICE

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627