


OFFICE USE ONLY
 Log No. 79459
 Permit No. _____
 Basin 230



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17797

1. OWNER Larry Williams ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS HCR 69 Box 481 Amargosa Valley, NV 89000
 2. LOCATION SW 1/4 Sec 11 T 16 N 16 R 48 E 104E County _____
 PERMIT NO. N/A Filed # 195444 Parcel # 3 Subdivision Name _____
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Mixed

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil + Sand		0	20	20
Gravel		20	40	20
Sand w/ clay pecks		40	70	30
Clay + Gravel		70	85	15
Permeated Sand		85	115	30
Gravel	1st	115	130	15
Gravel & Sand		130	145	15
Clay w/ some sand		145	160	15
Sand + Gravel		160	175	15
Gravel		175	180	5
Bottom of Hole				180'

8. WELL CONSTRUCTION
 Depth Drilled 180' Feet Depth Cased 180' Feet

HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 0 Feet 180 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>1" PVC</u>			<u>0</u>	<u>180</u>
<u>10" x 6" of steel</u>		<u>.188 wall</u>		

Perforations:
 Type perforation Machined
 Size perforation 3" x 7/8 every 12"
 From 140 feet to 180 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
 From 50 feet to 180 feet

Date started 5-4-00, 19____
 Date completed 5-6-00, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL
 Static water level 105 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 60 °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Cook Drilling Co. Contractor
 Address HCR 69 Box 452 Contractor
Amargosa Valley, NV 89000
 Nevada contractor's license number 05376-A
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 830
 Division of Water Resources, the on-site driller
 Signed Dave Row
 By driller performing actual drilling on site or contractor
 Date May 9, 2000