



OFFICE USE ONLY  
 Log No. 7946  
 Permit No. \_\_\_\_\_  
 Basin 163

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19790

1. OWNER PAUL MLINARIC ADDRESS AT WELL LOCATION TUSKEEGE + COPPER SANDY VALLEY  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION S 1/2 NE 1/4 SE 1/4 Sec 16 T. 24 N. R. 56 E. CLARK County  
 PERMIT NO. 200-16-801-010 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>SAUDY LOAM</u>		<u>0</u>	<u>4</u>	<u>4</u>
<u>CLAY + ROCK</u>		<u>4</u>	<u>34</u>	<u>30</u>
<u>CLAY</u>		<u>34</u>	<u>46</u>	<u>12</u>
<u>CALICHE</u>		<u>46</u>	<u>51</u>	<u>5</u>
<u>CLAY + GRAVEL</u>		<u>51</u>	<u>139</u>	<u>88</u>
<u>CALICHE</u>	<u>W.B</u>	<u>139</u>	<u>143</u>	<u>4</u>
<u>CLAY + GRAVEL</u>		<u>143</u>	<u>215</u>	<u>72</u>
<u>ROCK + GRAVEL</u>	<u>W.B</u>	<u>215</u>	<u>245</u>	<u>30</u>

8. WELL CONSTRUCTION  
 Depth Drilled 245 Feet Depth Cased 245 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0 To 245  
10 5/8 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>4.33</u>	<u>.316</u>	<u>0</u>	<u>245</u>

Perforations:  
 Type perforation FACTORY SAW CUT  
 Size perforation 8 INCH BY 8 INCH  
 From 245 feet to 205 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 245 feet to 50 feet

9. WATER LEVEL  
 Static water level 100 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.P.S.I.  
 Water temperature COOL °F Quality \_\_\_\_\_

Date started 4-24  
 Date completed 5-3

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name BUDGET DRILLING CO Contractor  
 Address P.O. BOX 3505 Contractor  
PATRUMP NV. 89041  
 Nevada contractor's license number issued by the State Contractor's Board 40020  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573  
 Signed Donnie Brown  
 By driller performing actual drilling on site or contractor  
 Date 5-10-2000