


OFFICE USE ONLY  
 Log No. 79471  
 Permit No. \_\_\_\_\_  
 Basin 230  
  
 NOTICE OF INTENT NO. 17799

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER: Apostolic Assembly of The Faith ADDRESS AT WELL LOCATION: \_\_\_\_\_  
 MAILING ADDRESS: P.O. Box 15210  
Amargosa Valley NV 89000  
 2. LOCATION: SE 1/4 NW 1/4 Sec. 15 T. 16 N. R. 48 E. Nye County  
 PERMIT NO. NIA Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil + Sand		0	26	26
Sandy Clay		26	54	28
Sand + Clay beds		54	65	11
Coarse Sand + gravel		65	105	40
Gravel + Clay		105	125	20
Gravel		125	134	9
Sand + Gravel		134	142	8
Clay + Gravel		142	156	14
Gravel		156	180	36
Bottom of Hole			180'	

8. WELL CONSTRUCTION  
 Depth Drilled 180 Feet Depth Cased 180 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 0 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6" PVC</u>			<u>0</u>	<u>180</u>
<u>6" 8' Steel</u>				
<u>Plastic casing</u>				

Perforations:  
 Type perforation Machined  
 Size perforation 3' x 7/8" every 10"  
 From 140 feet to 180 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 180' feet

9. WATER LEVEL  
 Static water level 97 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 60 °F Quality \_\_\_\_\_

Date started March 14 2000 79  
 Date completed March 16 2000 79

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge  
 Name Cook Drilling Co.  
 Address HCR 69 Box 450  
Amargosa Valley NV 89000  
 Nevada contractor's license number 5376-A  
 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the 830  
 Division of Water Resources, the on-site driller  
 Signed Dane Row  
 By driller performing actual drilling on site or contractor  
 Date March 25, 2000