WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 79487
Permit No.
Basin 216

NOTICE OF INTENT NO. 19747

1. OWNER DRY LAKE WATER CO.
MAILING ADDRESS
ADDRESS AT WELL LOCATION

2. LOCATION NE ¼ NE ¼ Sec 32 T 17 N/S R 63 E CLARK County
PERMIT NO. W-2088 (Issued by Water Resources) 084-32-000-001 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY & GRAVEL		0	460	460
CLAY, SAND & GRAVEL		460	770	310
STREAKS OF SANDY CLAY & CEMENTED GRAVEL		770	1020	250
LIMESTONE WITH STREAKS OF SANDSTONE	X	1020	1080	60
LIMESTONE	X	1080	1350	270
CEMENTED GRAVEL	X	1350	1365	15
LIMESTONE	X	1365	1400	35

Date started 4/27/00, 19XX
Date completed 5/5/00, 19XX

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 1400 Feet Depth Cased 1400 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11 Inches	0 Feet	1400 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5 5/8	10.9	.188	+2	1400

Perforations:
Type perforation SAW
Size perforation 1/8 X 3 5 ROWS
From 1040 feet to 1080 feet
From 1140 feet to 1180 feet
From 1240 feet to 1280 feet
From 1340 feet to 1380 feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 40
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 40 feet to 1400 feet

9. WATER LEVEL
Static water level 888 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WATER WELL SERVICES (Contractor)
Address 6475 GARY AVE. (Contractor)
LAS VEGAS, NV 89139

Nevada contractor's license number issued by the State Contractor's Board 22311B
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1594
Signed (By driller performing actual drilling on site or contractor)
Date 5/8/00

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627