

OFFICE USE ONLY  
 Log No. 19512  
 Permit No. 10  
 Basin 10  
 NOTICE OF INTENT NO. 29683

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Evelyn Stitilek ADDRESS AT WELL LOCATION 3410 Topaz St. Silver Springs, NV  
 MAILING ADDRESS 3310 Topaz St. Silver Springs, NV N/S R 28 E Lyon County  
 2. LOCATION SW 1/4 NW 1/4 Sec. 27 T. 18 PERMIT NO. 18-352-08 Parcel No. NO Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay + sand		0	18	
clay, cobbles + sand		18	58	
sand + clay		58	69	
clay + sand		69	115	
Rock boulders, clay sand		115	124	
clay + sand		124	205	
cemented clay + sand		205	300	

8. WELL CONSTRUCTION  
 Depth Drilled 300 Feet Depth Cased 300 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 50 Feet  
 From 6 Inches To 300 Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 7/8	7	1 1/8	0	300

 Perforations:  
 Type perforation factory  
 Size perforation 5/32 x 3  
 From 275 feet to 295 feet  
 Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
 Depth of Seal 50  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 9. WATER LEVEL  
 Static water level 178 feet below land surface  
 Artesian flow no G.P.M. 720 P.S.I.  
 Water temperature cold °F Quality \_\_\_\_\_

Date started Aug 16, 1999  
 Date completed March 4, 2000

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Bail tested 7 20 gpm</u>	<u>1.5 hrs</u>	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Ed Kawchack - H+H Pump  
 Address 15 Bobcat Rd Reno, NV 89523  
 Nevada contractor's license number issued by the State Contractor's Board 0031839  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1380  
 Signed Ed Kawchack  
 Date 3/5/2000