

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 79579
 Permit No. 8
 Basin MA
 NOTICE OF INTENT NO. 43095

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER M. GARMES ADDRESS AT WELL LOCATION 123 PEPPY SAN COURT
 MAILING ADDRESS 3015 SYDNEY CIRCLE WASHOE VALLEY, NV
CARSON CITY, NV 89701
 2. LOCATION SW 1/4 SE 1/4 Sec 5 T 16 S R 20 E WASHOE County
 PERMIT NO. 05030162 MA Subdivision Name
 Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Muo

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>AOLAN SEDIMENTS</u>		<u>0</u>	<u>2</u>	<u>2</u>
<u>SAND, V SML GRUBS</u>		<u>2</u>	<u>41</u>	<u>39</u>
<u>SANDS W V THIN</u>		<u>41</u>	<u>86</u>	<u>45</u>
<u>LT CLAYS</u>				
<u>ALT SANDS + SML GRUBS</u>	<u>X</u>	<u>86</u>	<u>173</u>	<u>84</u>
<u>MORE CLAYS, STILL</u>		<u>173</u>	<u>200</u>	<u>27</u>
<u>MINOR</u>				

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet
 HOLE DIAMETER (BIT SIZE)
 From 14 Inches To 0 Feet 200 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 7/8</u>		<u>0.188</u>	<u>+2</u>	<u>200</u>

Perforations:
 Type perforation SAWCUT / FACTORY
 Size perforation 3x 3/32
 From _____ feet to _____ feet
 From 140 feet to 200 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 52 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 200' feet

9. WATER LEVEL
 Static water level 34 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 60.0 °F Quality _____

Date started 2/7 1900
 Date completed 2/9 1900

7. WELL TEST DATA

TEST METHOD:		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>50+</u>		<u>4</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name NEVADA DRILLING, INC Contractor
 Address 75 LEWERS CRK RD Contractor
WASHOE VALLEY, NV 89704
 Nevada contractor's license number 13697 A
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the 1790
 Division of Water Resources the on-site driller.
 Signed Joe Feinick
 By Driller performing actual drilling on site or contractor
 Date 3/3/00