WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 79521
Permit No.
Basin 06

NOTICE OF INTENT NO. 33423

1. OWNER Dennis Mills
MAILING ADDRESS P.O. Box 801 Minden Nev. 89423
ADDRESS AT WELL LOCATION 3662 Quail Run Gardnerville Nev. 89410
2. LOCATION S ½ ¼ S ½ ¼ Sec. 16 T. 10 N/S R. 22 E. Douglas County
PERMIT NO. Issued by Water Resources | 37-630-160 Parcel No. | Pleasant Meadows Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
small sharp rock + top soil		0	17	17
sharp rock yellow clay		17	32	15
gravel	yes	32	45	13
sharp rock + yellow clay		45	87	42
gravel + sand	yes	87	120	33
Clay		120	134	14
gravel + sand	yes	134	150	16

RECEIVED 00 MAY 11 AM 10:53 STATE ENGINEER'S OFFICE

Date started April 17 00 ~~19~~
Date completed April 28 00 ~~19~~

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☑ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
22	7 ft	5 Hrs

8. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	50 Feet
6 Inches	50 Feet	150 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		188	0	150

Perforations:
Type perforation factory
Size perforation 3/32 x 3
From 100 feet to 150 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50 ft
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☑ No
From feet to feet

9. WATER LEVEL
Static water level 30 ft feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Edmund Miller Contractor
Address x 92 Smith Contractor 9410
Nevada contractor's license number issued by the State Contractor's Board 32166
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718
Signed Edmund Miller
By driller performing actual drilling on site or contractor
Date April 28 2000

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627