WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 79522
Permit No.
Basin 106

NOTICE OF INTENT NO. 33424

1. OWNER Robert H Smith
MAILING ADDRESS 1501 Hwy 395 Sp 74 Gardnerville Nev.
ADDRESS AT WELL LOCATION West Highway 208 APN 37-520-13

2. LOCATION SE ¼ SE ¼ Sec. 17 T. 10 N/S R. 22 E. Douglas County
PERMIT NO. 65494 Issued by Water Resources
37-520-13 Parcel No.
none Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☑ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
top soil		0	27	27
gravel + sand	✓	27	46	19
yellow clay + small strip rock		46	85	39
sand + gravel	✓	85	116	31
yellow clay		116	130	14
gravel + sand	✓	130	154	24
yellow clay		154	160	6

Date started April 26, 1990
Date completed May 6, 1990

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☑ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	5 ft.	3 hrs

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	50 Feet
6 Inches	50 Feet	160 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		188	0	160

Perforations:
Type perforation factory
Size perforation 3/32 x 3
From ~~3/32 x 3~~ feet to ~~120~~ 160 feet
From 120 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal 50 ft
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☑ No
From feet to feet

9. WATER LEVEL
Static water level 35 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Edmund Miller Contractor
Address P.O. Box 92 Smith Nev. 89430 Contractor
Nevada contractor's license number issued by the State Contractor's Board 3 66
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718
Signed Edmund Miller By driller performing actual drilling on site or contractor
Date May 6 - 90

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627