

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 43859

1. OWNER MIYSHAEL FRANCESJOHN & KATHRYN GAILSON ADDRESS AT WELL LOCATION  
P.O. Box 612 Ruby Hill Road  
Sparks, Nevada 89432 Reno, Nevada 89506

2. LOCATION NE 1/4 SE 1/4 Sec 35 T 23 N N/S R 19 E Washoe County  
 PERMIT NO. 079-530-09 Antelope Valley Area  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	2	2
Sandy clay with decomposed granite		2	18	16
Decomposed granite w/ sandy brown clay streaks		18	61	43
Weathered granite with clay streaks		61	121	60
Weathered granite		121	165	44
Gray granite		165	238	73
Soft rusty granite		238	241	3
Gray granite		241	283	42
Fracture (NO WATER)		283	284	1
Gray granite		284	427	143
Weathered soft granite with clay streaks		427	480	53
Weathered granite		480	577	97
Soft fracture granite	X	577	640	63
Gray granite		640	650	10

8. WELL CONSTRUCTION  
 Depth Drilled 650 Feet Depth Cased 650 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
10 Inches 0 Feet 50 Feet  
8 5/8 Inches 50 Feet 650 Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>0</u>	<u>650</u>

Perforations:  
 Type perforation factory sawed slot  
 Size perforation 3/32 x 3 x 5 around  
 From 586 feet to 646 feet  
 From..... feet to..... feet  
 From..... feet to..... feet  
 From..... feet to..... feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50 feet  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 650 feet

9. WATER LEVEL  
 Static water level 430 feet below land surface  
 Artesian flow..... G.P.M. 15 P.S.I.  
 Water temperature cold °F Quality clear

Date started March 15, 2000 ~~XXXX~~  
 Date completed March 22, 2000 ~~XXXX~~

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>15</u>		

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. Contractor  
 Address P.O. BOX 12370 Contractor  
RENO, NEVADA 89510

Nevada contractor's license number issued by the State Contractor's Board 0022549  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed [Signature] by driller performing actual drilling on site or contractor  
 Date March 22, 2000