WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 79564
Permit No.
Basin 85

NOTICE OF INTENT NO. 43065

1. OWNER JON COMBS
MAILING ADDRESS 423 E. 7th Avenue
Sun Valley, Nevada 89433

ADDRESS AT WELL LOCATION
Patrina Way
Sparks, Nevada 89436

2. LOCATION SE ¼ SW ¼ Sec. 4 T 20N N/S R 20E E Washoe County
PERMIT NO. (Issued by Water Resources) 083-440-66 (Parcel No.) Spanish Springs (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Weathered granite		1	4	3
Gray granite		4	37	33
Weathered granite		37	41	4
Gray granite		41	97	56
Green granite		97	157	60
Weathered granite with clay streaks		157	171	14
Green granite		171	222	51
Fracture (app 2 GPM)	X	222	223	1
Soft weathered granite		223	293	70
Fracture	X	293	302	9
Weathered granite		302	322	20
Fracture granite	X	322	330	8
Gray granite		330	349	19
Weathered granite		349	350	1

Date started May 1, 2000
Date completed May 3, 2000

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		

8. WELL CONSTRUCTION
Depth Drilled 350 Feet Depth Cased 350 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	350 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	350

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 285 feet to 305 feet
From 325 feet to 345 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50 foot
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 350 feet

9. WATER LEVEL
Static water level 199 feet below land surface
Artesian flow G.P.M. 30 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510

Nevada contractor's license number issued by the State Contractor's Board 0022549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed (By driller performing actual drilling on site or contractor)
Date May 4, 2000

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627