

OFFICE USE ONLY  
 Log No. 79569  
 Permit No. \_\_\_\_\_  
 Basin. 102

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT 10/27/94

1. OWNER Hernandez ADDRESS AT WELL LOCATION 5475 Greely St. Silver Springs, Nevada  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION NE 1/4 NW 1/4 Sec. 32 T. 18 N/S R. 24 E. Lyon County  
 PERMIT NO. 18-452-01 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other well

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Boulders sand</u>		<u>0</u>	<u>126</u>	
<u>Cemented boulders</u>		<u>126</u>	<u>193</u>	
<u>Clay</u>		<u>193</u>	<u>231</u>	
<u>Gravels cemented</u>		<u>231</u>	<u>311</u>	
<u>Gravels Boulders</u>		<u>311</u>	<u>360</u>	

8. WELL CONSTRUCTION  
 Depth Drilled 360 Feet Depth Cased 360 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10.518 Inches 0 Feet 60 Feet  
8.214 Inches 60 Feet 360 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.578</u>	<u>13.00</u>	<u>3/16</u>	<u>11</u>	<u>20</u>
<u>6.578</u>	<u>13.00</u>	<u>5/16</u>	<u>20</u>	<u>360</u>

Perforations:  
 Type perforation Spill Saw  
 Size perforation 1 1/4 G.L. 5/16" dia  
 From 320 feet to 360 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 0-50  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 360 feet

9. WATER LEVEL  
 Static water level 285 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 3-8 2000  
 Date completed 3-10 2000

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
	<u>Produced about 15 GPM</u>		

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Leigh Poling Inc Contractor  
 Address P.O. Box 579 Silver Springs NV 89429 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 0031841  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1877 877  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 3-10-00