

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTEREST NO. 40771

1. OWNER JIM + Annette Brady ADDRESS AT WELL LOCATION 1350 E. ANTELOPE ST SILVER SPRING, NV
MAILING ADDRESS _____
2. LOCATION SE 1/4 NW 1/4 Sec 19 T. 17 N/S R. 25 E County NGON
PERMIT NO. 17-422-03 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND & SILT.		0	6'	6'
Clay light Brown		6'	60'	54
Fine Sand	✓	60	85'	25
COURSE SAND	✓	85	100'	15

RECEIVED
 COPY - 3 P 12:31
 STATE ENGINEERING OFFICE

8. WELL CONSTRUCTION
Depth Drilled 100' Feet Depth Cased 101' Feet
HOLE DIAMETER (BIT SIZE)
From 0 Feet To 100' Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.00</u>	<u>1.88</u>	<u>+1</u>	<u>19-6'</u>
<u>6 5/8</u>		<u>1.40</u>	<u>19-6</u>	<u>100'</u>

Perforations:
Type perforation SAW CUT
Size perforation 1/8" x 3" 4 ROWS
From 85' feet to 100' feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50' Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 50' feet to 100' feet

9. WATER LEVEL
Static water level 33' feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature Cold °F Quality Clear

Date started Apr 19/00 19____
Date completed April 19/00 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>75 gpm</u>	<u>4' dia</u>	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Jack Drilling Inc. Contractor
Address PO Box 599 Contractor
Silver Springs NV. 89429
Nevada contractor's license number 0031841
issued by the State Contractor's Board.
Nevada driller's license number issued by the 1740
Division of Water Resources, the on-site driller.
Signed Michael DeLeon
By driller performing actual drilling on site or contractor
Date 3/31/00